



**NOTES:**

1. CONFIGURATION FOR FIRE HYDRANT INSTALLATION WITH TAPPING VALVE. IN THE CASE OF FIRE HYDRANT INSTALLATION WITH TEE AND VALVE PLATED TIE RODS ARE TO BE INSTALLED WITH SAC CAPS.
2. ALL HYDRANTS ON PUBLIC R.O.W SHALL BE FLOW TESTED.



No.	Revision Date	No.	Revision Date
		1	MARCH 18, 2020