



NOMINAL DIA. (mm)	TRENCH WIDTH (mm)	
	MIN.	MAX.
25	650	775
50	650	775
100	650	775
150	650	775
200	700	825
250	750	875
300	800	950

NOTE:

1. ALL WATERMANS TO BE INSTALLED AT 1.68M± (0.3M) DEPTH UNLESS OTHERWISE DIRECTED BY THE ENGINEER.
2. USE 600mm COVER IN AREAS WHERE BACKFILL AGGREGATE SIZE EXCEEDS 19mm DIA.
3. WHERE TWO WATER SERVICE PIPES ARE INSTALLED IN SAME TRENCH THE CLEAR DISTANCE BETWEEN PIPES SHALL BE 1000mm MIN.
4. TRENCH WIDTH, BEDDING AND COVER FOR PIPING GREATER THAN 300mm IN DIA. SHALL BE APPROVED BY WUC.



No.	Revision Date	No.	Revision Date
		1	March 18, 2020