

OPTIONAL ANNUAL REPORT TEMPLATE

Drinking Water System Number:
 Drinking Water System Name:
 Drinking Water System Owner:
 Drinking Water System Category:
 Period being reported:

220004402
Town of Lasalle Distribution System
Corporation of The Town of Lasalle
Large Municipal Residential
January 1, 2024 to December 2024

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking Water System serve more than 10,000 people? Yes [x] No []

Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Town of Lasalle
 Public Works Department
 2170 Judy Recker Crescent, Lasalle
 N9J 0C3

Complete for all other Categories

Number of Designated Facilities served:

N/A

Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []

Number of Interested Authorities you report to:

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []

Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report

Indicate how you notified system users that your annual report is available and is free of charge.

- [x] Public access/notice via the web
- [] Public access/notice via Government Office
- [] Public access/notice via a newspaper
- [x] Public access/notice via Public Request
- [] Public access/notice via a Public Library
- [] Public access/notice via other method _____

Describe your Drinking Water System

Town of Lasalle Distribution Systems receives treated water from the Enwin Utilities via seven (7) feeder mains and supplies approximately 11,403 accounts for residences and businesses.

Please provide a brief description and a breakdown of monetary expenses incurred

590 meters of 200mm PVC Watermain replacement on Malden Rd. - \$500,000
540meters of 200mm PVC Watermain replacement on Cabot Ave. \$500,000

Provide details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
July 23, 2024	Microbiological	Total Coliform 20 E. coli 20	CFU/100mL	Flush and resample Boil water advisory	July 23, 2024

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

	Number of Samples	Range of E. Coli Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Distribution	572	0-20 cfu/100mL	0-20 cfu/100mL	156	<10-20

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	Please review Enwin Utilities (220003421) Annual Report		
Chlorine	968	0.21-1.43	mg/L

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	N/A	N/A	N/A	N/A
Distribution	8	0.01-0.18	ug/L	N/A

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
HAAs (<i>Note: show latest running annual average</i>)	Jan 8 April 0 July 15 Oct 21	4.8	ug/L	0
THMs (<i>Note: show latest running annual average</i>)	Jan 8 April 9 July 15 Oct 21	26	ug/L	0