



NOTE:
 19mm / 25mm MAIN STOP AND SERVICE SADDLES TO BE NEW MATERIAL
 THE 19mm / 25mm RISER PIPE, VALVE AND PLUG MUST BE CLEAN AND IN GOOD OPERATING CONDITION
 CLOSE MAINSTOP. CHLORINE RISER TO BE REMOVED AFTER TESTING AND DISINFECTION OF WATERMAIN IS COMPLETED

NEW WATERMAIN WILL NOT BE PLACED IN SERVICE UNTIL REMOVAL HAS BEEN COMPLETED

TOWN STAFF MUST BE PRESENT ON SITE TO WITNESS THE REMOVAL OPERATION
 IN WINTER CONDITIONS THE EXPOSED PIPE TO BE ADEQUATELY INSULATED TO PREVENT FREEZING

NOTE:
 PVC TEES ALSO ACCEPTABLE

NOTE:
 ALL CHLORINE RISER AND SAMPLING POINT ASSEMBLIES SHALL BE CONSTRUCTED FROM NEW MATERIALS.



No.	Revision Date	No.	Revision Date
1	March 18, 2020		